



Annual Fire Pump Test Results

Date of Test:	12/9/21
Location in Site:	Building 2
Pump Type:	Horizontal Split-Case
Driver Type:	Electric
Technician:	Ginny Allen
Flow Device Used:	Test Header

	Pressures				Streams					Total Flow		Volts	Amps
	RPM	Suction	Discharge	Net	Flow	1	2	3	4	Flow GPM	% Rated Capacity		
Churn	1791	10	110	100	Pitot Size					0	0%	477	56
					PSI								
					GPM								
100%	1789	5	106	101	Pitot Size	2.5				1501	100%	479	90
					PSI	17							
					GPM	1501							
150%	1777	6	96	90	Pitot Size	2.5				2252	150%	477	118
					PSI	17							
					GPM	2252							

