


Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Address
City		City St. Zip
Contact Person	License #	Phone
	<input type="checkbox"/> SFM	Job #
	<input type="checkbox"/> CSLB	Misc.

Riser Information			Main Drain Test (Annual)				
Riser No.	Location	Riser Diameter	Main Drain Diameter	Initial Static Pressure	Residual Pressure	Final Static Pressure	P,F,N/A

This building has more than 5 risers. See additional AES 2.9 form attached. Number of AES 2.9 forms attached

Quarterly Inspections								
		I = Inspection	T = Test	M = Maintenance	P = Pass F = Fail N/A = Not Applicable			
Item	Description	NFPA 25 CA ed. Reference	Date	Date	Date	Date	Date	
1.1	I Control Valves – Identification Sign	13.3.1						
1.2	I Control Valves – Inspection	13.3.2						
1.3	I Waterflow Alarm Devices	5.2.5						
1.4	I Supervisory Devices	5.2.5						
1.5	I Gauges (Wet Pipe Systems)	5.2.4.1						
1.6	I Enter Water Supply Pressure Below Riser Check	5.2.4.1		psi		psi		
1.7	I Enter Water Supply Pressure Above Riser Check	5.2.4.1		psi		psi		
1.8	I Pressure Readings Acceptable	5.2.4.1						
1.9	I Hydraulic Design Information Sign <i>(For Hydraulically Designed Systems)</i>	5.2.6						
1.10	I General Information Sign <i>(Not Required for System prior to 2007 Edition of NFPA 13)</i>	5.2.8						
1.11	I Heat Tape	5.2.7						
1.12	I Spare Sprinklers	5.2.1.4						
1.13	I Fire Department Connections	13.7						
1.14	I Alarm Valves – Exterior Inspection	13.4.1						
1.15	I Pressure Reducing Valves	13.5.1.1						
1.16	I Backflow Preventers	13.6.1						
1.17	I Small Hose Connections - Hose Valve*	5.1.6, 13.5.2 13.5.5.1						
1.18	I PRV – Fire Sprinkler Systems	13.5.1.1						

* Small hose connections are hose valves and optional hose supplied by the fire sprinkler system. They do not include Class I, II, or III standpipe systems.

Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Job #
City		

ANNUAL INSPECTION, TESTING, AND MAINTENANCE
Include ALL Quarterly Inspections

I = Inspection T = Test M = Maintenance P = Pass F = Fail N/A = Not Applicable

Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
1.19	I	Sprinklers	5.2.1			
1.20	I	Buildings (Freeze Protection)	4.1.1.1		Owner's Responsibility	
1.21	I	Pipe and Fittings	5.2.2			
1.22	I	Hangers	5.2.3			
1.23	I	Seismic Braces	5.2.3			
2.1	T	Field Service Test Required <i>(Send Report to Fire Code Official)</i>	5.3.1		If REQUIRED, Enter 'F' until results are returned from Lab	
2.2	T	Recalled Sprinklers <i>If not present = Pass; If present = Fail</i>	Title 19 904.1(c)			
2.3	T	Water Flow Alarm Devices <i>90 sec. maximum - (Enter Time)</i>	5.3.3 13.2.6		sec.	
2.4	T	Main Drain Test <i>(Enter Data on Page 1 of this Form)</i>	13.2.5 13.3.3.4			
2.5	T	Control Valve - Position	13.3.3.2			
2.6	T	Control Valve – Operation	13.3.3.1			
2.7	T	Supervisory Devices	13.3.3.5			
2.8	T	Backflow Preventer Assemblies	13.6.2			
2.9	T	Small Hose Connections* <i>w/PRV Hose Valves – Partial Flow Test</i>	13.5.2.3 13.5.3.3			
2.10	T	PRV – Fire Sprinkler Systems	13.5.1.3			
3.1	M	Control Valves	13.3.4			
3.2	M	Small Hose Connections*	13.5.6.3			
3.3	M	Obstruction Investigation required <i>(If "Yes", see Deficiencies and Comments Section for Results.)</i>	14.3		<input type="checkbox"/> Yes <input type="checkbox"/> No	
3.4	M	System Returned to Service	4.5.3		<input type="checkbox"/> Yes <input type="checkbox"/> No	

* Small hose connections are hose valves and optional hose supplied by the fire sprinkler system. They do not include Class I, II, or III standpipe systems.

D = Deficiency C = Comment (Indicate type)

Item	Date	Riser	D	C	Deficiencies and Comments <i>Indicate all equipment, devices and parts that were repaired or replaced</i>

